

March 28, 2011

Nuclear and Industrial Safety Agency

**Regarding the result of concentration measurement in the stagnant water on
the basement floor of the turbine building of
Unit 2 of Fukushima Dai-ichi Nuclear Power Station**

1. Regarding the captioned result of the measurement announced by Tokyo Electric Power Co. (TEPCO) yesterday, TEPCO reported to NISA the result of analysis and evaluation through re-sampling, judging the measured value of ionide-134 was wrong. The outline is as attached.
2. Since it was a mistake in the evaluation regarding the concentration measurement of important radioactive materials, NISA directed TEPCO orally to prevent the recurrence of such a mistake.

Appendix: The results of the measurement of puddle of water in the basement of the turbine building of Unit 2 of Fukushima Daiichi Nuclear Power Station.(2nd release)

http://www.tepco.co.jp/en/press/corp-com/release/betu11_e/images/110327e15.pdf

(Contact Person)

Mr. Toshihiro Bannai

Director, International Affairs Office,
NISA/METI

Phone:+81-(0)3-3501-1087

March 28, 2011

Nuclear and Industrial Safety Agency

Seismic Damage Information (the 59th Release)
(As of 15:00 March 28th, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

- Fukushima Dai-ichi NPS

2. Action taken by NISA

(March 28th)

13:50 Receiving the suggestion by the special meeting of Nuclear Safety Commission (Stagnant water on the underground floor of the turbine building at Fukushima Dai-ichi Plant Unit 2), NISA directed TEPCO orally to add the sea water monitoring points and carry out the underwater monitoring.

< Possibility on radiation exposure (workers)>

All three workers who have been monitoring in the National Institute of Radiological Sciences since 24 March have discharged from the hospital around the noon 28 March.

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

March 28, 2011

Nuclear and Industrial Safety Agency

Seismic Damage Information (the 58th Release)
(As of 08:00 March 28th, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- The pump for the fresh water injection to Reactor Pressure Vessel of Unit 2 was switched from the Fire Pump Truck to the temporary motor-driven pump.(18:31 March 27th)
- Regarding the result of the concentration measurement in the stagnant water on the basement floor of the turbine building of Unit 2 of Fukushima Dai-ichi NPS announced by TEPCO on 27 March, TEPCO reported to NISA that as the result of analysis and evaluation through re-sampling, judging the measured value of Iodine-134 was wrong, the concentrations of gamma nuclides including Iodine-134 were less than the detection limit.(00:07 March 28)
- Regarding the mistake in the evaluation of the concentration measurement, NISA directed TEPCO orally to prevent the recurrence of such a mistake.
- Water spray using Concrete Pump Truck (50t/h) was carried out.
- As the result of nuclide analysis at around the southern Water Discharge Canal, $7.4 \times 10^1 \text{Bq/cm}^3$ of ^{131}I (Iodine) (1,850.5 times higher than the concentration limit in water outside the Environmental Monitoring Area) was detected. (14:30 March 26th) (As the result of measurement on 27 March, it was detected as 250 times higher than the limit in water. On the other hand, as the result of the analysis at the north side of the Water Discharge Canal of the NPS, $4.6 \times 10^1 \text{Bq/cm}^3$ of ^{131}I (Iodine) (1,150 times higher than the limit) was detected. (14:05 March 27th))

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

Fukushima Di-ichi Nuclear Power Station Major Parameters of the Plant (As of 06:00, March 28th)

Unit No.	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Situation of water injection	Injecting freshwater via the Water Supply Line. Flow rate of injected water : 113 ℓ/min (As of 14:00, March 27th) temporary measuring instrument	Injecting freshwater via the Fire Extinguish Line. Flow rate of injected water :117 ℓ/min (As of 0:12, March 28th) temporary measuring instrument	Injecting freshwater via the Fire Extinguish Line. Flow rate of injected water: 210 ℓ/min (As of 14:00, March 27th) temporary measuring instrument	Under shutdown	Under shutdown	Under shutdown
Reactor water level	Fuel range A : -1,700mm Fuel range B : -1,650mm (As of 3:00, March 28th)	Fuel range A : -1,500mm (As of 4:00, March 28th)	Fuel range A:-1,900mm Fuel range B:-2,300mm (As of 5:30, March 28th)	#2	Shutdown range measurement 1,948mm (As of 06:00, March 28th)	Shutdown range measurement 1,933mm (As of 06:00, March 28th)
Reactor pressure	0.376MPa g(A) 0.443MPa g(B) (As of 3:00, March 28th)	-0.020MPa g (A) -0.023MPa g (B) (As of 4:00, March 28th)	0.029MPa g (A) -0.090MPa g (C) (As of 5:30, March 28th)	#2	0.007MPa g (As of 6:00, March 28th)	0.005MPa g (As of 06:00, March 28th)
Reactor water temperature	(Impossible collection due to low system flow rate)			#2	57.7℃ (As of 6:00, March 28th)	21.9℃ (As of 6:00, March 28th)
Reactor Pressure Vessel (RPV) temperature	Feedwater nozzle temperature: 273.8℃ Temperature at the bottom head of RPV: 139.2℃ (As of 3:00, March 28th)	Feedwater nozzle temperature: 130.3℃ Temperature at the bottom head of RPV: 81.5℃ (As of 4:00, March 28th)	Feedwater nozzle temperature: 38.0℃ (under survey) Temperature at the bottom head of RPV: 123.0℃ (As of 5:30, March 28th)	Unit 4 No heating element (fuel) inside the reactor Unit 5,6 Monitoring by the reactor water temperature		
D/W*1 Pressure, S/C*2 Pressure	D/W: 0.270MPa abs S/C: 0.270MPa abs (As of 3:00, March 28th)	D/W: 0.110MPa abs S/C:Down scale (under survey) (As of 4:00, March 28th)	D/W: 0.1083MPa abs S/C: 0.1794MPa abs (As of 5:30, March 28th)	#2		
CAMS*3	D/W: 3.38×10^1 Sv/h S/C: 2.13×10^1 Sv/h (As of 3:00, March 28th)	D/W: 4.05×10^1 Sv/h S/C: 1.37×10^0 Sv/h (As of 4:00, March 28th)	D/W: 3.15×10^1 Sv/h S/C: 1.24×10^0 Sv/h (As of 5:30, March 28th)	#2		
D/W*1 design operating pressure	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	#2		
D/W*1 maximum operating pressure	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)	#2		
Spent Fuel Pool water	#1	47℃ (As of 4:00, March 28th)	#1	#1	34.5℃ (As of 6:00, March 28th)	27.5℃ (As of 6:00, March 28th)
FPC skimmer level	4,500mm (As of 3:00, March 28th)	5,750mm (As of 4:00, March 28th)	#1	5,850mm (As of 5:30, March 28th)	#2	
Power supply	Receiving external power supply (P/C*4 2C)		Receiving external power supply (P/C4D)		Receiving external power supply	


Other information	Unit3: Collecting the data of RPV temperature and continuing survey for transitional situation Unit2: Confirmed the indicated value of S/C Pressure but continuing to survey the transition of condition	Common pool: about 39 °C (As of 8:00, March 27th)	Unit5:Nonthermal mode (From 21:00 March 27th)	Unit6:SHC mode (From 10:14 March 27th)
-------------------	---	---	---	--

Pressure conversion Gauge pressure (MPa g) = Absolute pressure (MPa abs) – Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)
 Absolute pressure (MPa abs) = Gauge pressure (MPa g) + Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)

- *1 D/W : Dry Well
- *2 S/C : Suppression Chamber
- *3 CAMS : Containment Atmospheric Monitoring System
- *4 P/C : Power Center

- #1 : Measuring instrument malfunction
- #2 : Except from data collection


Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 1 (As of 6:00 March 28th, 2011)



Current Conditions : Fresh water is being injected to the core

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)


Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 2 (As of 6:00 March 28th, 2011)




Current Conditions: Sea water is being injected to the Spent Fuel Pool and fresh water is being injecting to the core

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)


Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 3 (As of 6:00 March 28th, 2011)




Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 4 (As of 6:00 March 28th, 2011)



Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 5 (As of 6:00 March 28th, 2011)



Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 6 (As of 6:00 March 28th, 2011)



Press Releases

Press Release (Mar 27,2011)

The results of the measurement of puddle of water in the basement of the turbine building of Unit 2 of Fukushima Daiichi Nuclear Power Station(2nd release)

With regard to the captioned result of the measurement that was previously announced, we have judged that the estimation concerning the measured value of iodine-134 was wrong.

Therefore we informed that we would take, analyze and evaluate samples, and announce the results once we have summarized the results.

(previously announced)

Since then we have taken samples and analyzed and evaluated the density of the gamma nuclide including iodine-134, and now we announce the summary of the results of the measurements as shown in the attachment.

Appendix:Result of Contamination Check of Water in the Basement At the Turbine Building of Each Unit 2 of Fukushima Daiichi Power Station(PDF 14.1KB)

[☐ back to page top](#)

March 27th, 2011

**Result of Contamination Check of Water in the Basement
At the Turbine Building of Each Unit 2 of Fukushima Daiichi Power Station**

Radioactive Materials (T1/2)	Density of Radioactive Materials (Bq/cm ³)			
	Unit 2 (Error)	Unit 2 (Reassessment)	Unit 2 (re-measurement)	Unit 2 (re-extraction)
	Obtained at around 8:50 on March 26 Measured at around 18:50 March 26	Obtained at around 8:50 on March 26 Measured at around 18:50 March 26	Obtained at around 8:50 on March 26 Measured at around 12:50 March 27	Obtained at around 20:40 on March 27 Measured at around 22:30 March 27
	Radiation Dose Rate in the Surface of Water >1,000mSv/h,	Radiation Dose Rate in the Surface of Water >1,000mSv/h,	Radiation Dose Rate in the Surface of Water >1,000mSv/h,	
Co-56 (approx. 77days)	1.6×10^5	under the limit	under the limit	under the limit
Co-58 (approx. 71days)	under the limit	under the limit	under the limit	under the limit
Co-60 (approx. 5 years)	under the limit	under the limit	under the limit	under the limit
Mo-99 (approx. 66hours)	under the limit	under the limit	under the limit	under the limit
Tc-99m (approx. 6 hours)	8.7×10^4	8.7×10^4	4.8×10^5	under the limit
Ru-106 (approx. 370days)	under the limit	under the limit	under the limit	under the limit
Ag-108m	2.5×10^5	under the limit	under the limit	under the limit

(approx. 418 年)				
Te-129 (approx. 70mins)	under the limit	under the limit	under the limit	under the limit
Te-129m (approx. 34days)	under the limit	under the limit	under the limit	under the limit
Te-132 (approx. 3days)	under the limit	under the limit	under the limit	under the limit
I-131 (approx. 8days)	1.3×10^7	1.3×10^7	1.3×10^7	1.3×10^7
I-132 (approx. 2hours)	under the limit	under the limit	under the limit	under the limit
I-134 (approx. 53mins)	2.9×10^9	under the limit	under the limit	under the limit
Cs-134 (approx. 2 years)	2.3×10^6	2.3×10^6	2.2×10^6	3.1×10^6
Cs-136 (approx. 13 days)	2.5×10^5	2.5×10^5	2.5×10^5	3.2×10^5
Cs-137 (approx. 30 years)	2.3×10^6	2.3×10^6	2.2×10^6	3.0×10^6
Ba-140 (approx. 13 days)	4.9×10^5	4.9×10^5	4.9×10^5	6.8×10^5
La-140 (approx. 2 days)	1.9×10^5	1.9×10^5	1.8×10^5	3.4×10^5
Total	2.9×10^9	1.9×10^7	1.9×10^7	2.0×10^7