

April 1, 2011

Nuclear and Industrial Safety Agency

Seismic Damage Information (the 67th Release)
(As of 15:30 April 1st, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- In order to prepare to transfer the stagnant water on the basement floor of turbine building of Unit 2 to the Condenser, the water in the Condensate Storage Tank was transferred to the Surge Tank of Suppression Pool Water. (16:45 March 29th till 11:50 April 1st)
- The injection of fresh water to the Spent Fuel Pool of Unit 2 via the Spent Fuel Pool Cooling Line was started. (14:56 April 1st)
- Spray of around 180t of fresh water for Unit 4 using Concrete Pump Truck (50t/h) was carried out. (From 08:28 till 14:14 April 1st)
- The transfer of fresh water from the barge to the Filtrate Tank was started. (15:58 April 1st) Thereafter it was suspended due to the malfunction of the hose.

< Possibility on radiation exposure >

1. Exposure of residents

In Fukushima Prefecture, up until March 30th, the screening was done to 110,340 people. Among them, 102 people were at the level above the 100,000cpm, but when measured these people again without clothes, etc., the counts decreased to 100,000cpm and below, and there was no case which affects health.

2. Exposure of workers

- At around 11:35 April 1st, a worker fell into the sea when he wet on board the barge of the US Armed forces in order to adjust the hose. He was rescued immediately by other workers around without any injury, etc. However, as the surface contamination was noticed, he was decontaminated by having a shower. As a result of nasal smear*, the internal radionuclide contamination was not confirmed.

*) nasal smear: to estimate the existence of internal radioactive contaminant taken in through sampling the radioactive material in nostril

<Directives regarding foods and drinks>

- The scope of request for restriction of drinking for tap-water was updated.
(As of 09:00 April 1st)

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

April 2, 2011

Nuclear and Industrial Safety Agency

Seismic Damage Information (the 68th Release)
(As of 08:30 April 2nd, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- In order to prepare to transfer the stagnant water on the basement floor of the turbine building of Unit 2 to the Condenser, the water in the Condensate Storage Tank was transferred to the Surge Tank of Suppression Pool Water. (From 16:45 March 29th till 11:50 April 1st)
- Injection of around 70t of fresh water to the Spent Fuel Pool of Unit 2 via the Spent Fuel Cooling Line using the temporary pump was carried out. (From 14:56 till 17:05 April 1st)
- Spray of around 180t of fresh water for Unit 4 using Concrete Pump Truck (50t/h) was carried out. (From 08:28 till 14:14 April 1st)
- The transfer of fresh water from the barge to the Filtrate Tank was started. (15:58 April 1st) Thereafter it was suspended by the malfunction of the hose (disconnection).
- The permanent monitoring posts (No.1 to 8) installed near the Site Boundary were recovered. (March 31st) They are measuring once a day.

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

Fukushima Di-ichi Nuclear Power Station Major Parameters of the Plant (As of 6:00, April 2nd)

Unit No.	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Situation of water injection	Injecting fresh water via the Water Supply Line. Flow rate of injected water : 117 l/min (As of 16:18, April 1st) temporary measuring instrument	Injecting fresh water via the Fire Extinguish Line. Flow rate of injected water : 150 l/min (As of 14:00, March 30th) temporary measuring instrument	Injecting fresh water via the Fire Extinguish Line. Flow rate of injected water: 116 l/min (As of 14:39, March 29th) temporary measuring instrument	Under shutdown	Under shutdown	Under shutdown
Reactor water level	Fuel range A : -1,600mm Fuel range B : -1,600mm (As of 4:00, April 2nd)	Fuel range A : -1,500mm (As of 4:00, April 2nd)	Fuel range A: -1,850mm Fuel range B: -2,250mm (As of 1:30, April 2nd)	#2	Shutdown range measurement 1,799mm (As of 6:00, April 2nd)	Shutdown range measurement 1,534mm (As of 6:00, April 2nd)
Reactor pressure	0.288MPa g(A) 0.520MPa g(B) (As of 4:00, April 2nd)	-0.011MPa g (A) -0.014MPa g (B) (As of 4:00, April 2nd)	0.025MPa g (A) -0.086MPa g (C) (As of 1:30, April 2nd)	#2	0.007MPa g (As of 6:00, April 2nd)	0.005MPa g (As of 6:00, April 2nd)
Reactor water temperature	(Impossible collection due to low system flow rate)			#2	35.5°C (As of 6:00, April 2nd)	21.6°C (As of 6:00, April 2nd)
Reactor Pressure Vessel (RPV) temperature	Feedwater nozzle temperature: 261.5°C Temperature at the bottom head of RPV: 118.0°C (As of 4:00, April 2nd)	Feedwater nozzle temperature: 155.0°C Temperature at the bottom head of RPV: #1 (As of 4:00, April 2nd)	Feedwater nozzle temperature: 90.8°C (under survey) Temperature at the bottom head of RPV: 119.4°C (As of 1:30, April 2nd)	Unit 4 No heating element (fuel) inside the reactor Unit 5,6 Monitoring by the reactor water temperature		
D/W*1 Pressure, S/C*2 Pressure	D/W: 0.160MPa abs S/C: 0.160MPa abs (As of 4:00, April 2nd)	D/W: 0.110MPa abs S/C: Down scale (under survey) (As of 4:00, April 2nd)	D/W: 0.1055MPa abs S/C: 0.1748MPa abs (As of 1:30, April 2nd)	#2		
CAMS*3	D/W: 4.55×10^{-1} Sv/h S/C: 1.65×10^{-1} Sv/h (As of 4:00, April 2nd)	D/W: 3.61×10^{-1} Sv/h S/C: 9.81×10^{-1} Sv/h (As of 4:00, April 2nd)	D/W: 2.40×10^{-1} Sv/h S/C: 9.55×10^{-1} Sv/h (As of 1:30, April 2nd)	#2		
D/W*1 design operating pressure	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	0.384MPa g(0.485MPa abs)	#2		
D/W*1 maximum operating pressure	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)	0.427MPa g(0.528MPa abs)	#2		
Spent Fuel Pool water	#1	72.0°C (As of 4:00, April 2nd)	#1	#1	34.1°C (As of 6:00, April 2nd)	27.0°C (As of 6:00, April 2nd)
FPC skimmer level	4,500mm (As of 4:00, April 2nd)	#1 (As of 4:00, April 2nd)	#1	5100mm (As of 1:30, April 2nd)	#2	
Power supply	Receiving external power supply (P/C*4 2C)		Receiving external power supply (P/C4D)		Receiving external power supply	


Other information	Unit3: Collecting the data of RPV temperature and continuing survey for transitional situation Unit2: Confirmed the indicated value of S/C Pressure but continuing to survey the transition of condition Unit2: Indication failure of FPC skimmer level by a fall in battery pressure	Common pool: about 32 °C (As of 7:30, April 1st)	Unit5:Nonthermal mode (From 22:12 April 1st)	Unit6:SHC*5 mode (From 11:39 April 1st)
-------------------	---	--	--	---

Pressure conversion	$\text{Gauge pressure (MPa g)} = \text{Absolute pressure (MPa abs)} - \text{Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)}$ $\text{Absolute pressure (MPa abs)} = \text{Gauge pressure (MPa g)} + \text{Atmospheric pressure (Normal atmospheric pressure 0.1013MPa)}$
---------------------	---


- *1 D/W : Dry Well
- *2 S/C : Suppression Chamber
- *3 CAMS : Containment Atmospheric Monitoring System
- *4 P/C : Power Center
- *5 SHC : Shutdown Cooling

- #1 : Measuring instrument malfunction
- #2 : Except from data collection


Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 1 (As of 6:00 April 2nd, 2011)



Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 2 (As of 6:00 April 2nd, 2011)



Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 3 (As of 6:00 April 2nd, 2011)




Major Events after the earthquake

- 11th 14:46 Under operation. Automatic shutdown by the earthquake
- 11th 15:42 Report based on the Article 10 (Total loss of A/C power)
- 13th 05:10 Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System)
- 13th 08:41 Started to vent.
- 13th 13:12 Started to inject seawater and borated water to core.
- 14th 05:20 Started to vent.
- 14th 07:44 Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)
- 14th 11:01 Sound of explosion
- 16th around 08:30 White smoke generated.
- 17th 09:48~10:01 Water discharge by the helicopters of Self-Defense Force
- 17th 19:05~19:15 Water spray from the ground by High pressure water-cannon trucks of Police
- 17th 19:35~20:09 Water spray from the ground by fire engines of Self-Defense Force
- 18th before 14:00~14:38 Water spray from the ground by 6 fire engines of Self-Defense Force
- 18th ~14:45 Water spray from the ground by a fire engine of the US Military
- 19th 00:30 ~01:10 Water spray by Hyper Rescue Unit of Tokyo Fire Department
- 19th 14:10 ~ 20th 03:40 Water spray by Hyper Rescue Unit of Tokyo Fire Department
- 20th 11:00 Pressure of PCV rose(320kPa).Afterward fell.
- 20th 21:36 ~ 21st 03:58 Water spray by Hyper Rescue Unit of Tokyo Fire Department
- 21st about 15:55 Grayish smoke generated and was confirmed to be died down at 17:55.
- 22nd 15:10 ~16:00 Water spray by Hyper Rescue Unit of Tokyo Fire Department and Osaka City Fire Bureau.
- 22nd 22:46 Lighting in the Central Control Room was recovered.
- 23rd 11:03 ~13:20 Injection of about 35ton of sea water to the Spent Fuel Pool (SFP) via the Fuel Pool Cooling Line (FPC)
- 23rd around 16:20 Black smoke generated and was confirmed to be died down at around 23:30 and 24th 04:50.
- 24th 05:35~16:05 Approximately 120 ton sea water injection to SFP via FPC
- 25th 13:28~16:00 Water spray by Kawasaki City Fire Bureau supported by Tokyo Fire Department
- 25th 18:02 Started fresh water injection to the core.
- 27th 12:34~14:36 Water spray by Concrete Pump Truck
- 28th 17:40~31st 8:40 Transferring the stagnant water from the Condensate Storage Tank (CST) to the Surge Tank of Suppression Pool Water (SPT) from the condensate storage tank (CST) to the suppression pool water surge tank (SPT)
- 28th 20:30 Switched to the water injection to the core using a temporary motor-driven pump.
- 29th 14:17~18:18 Fresh water spray by Concrete Pump Truck
- 31st 16:30~19:33 Fresh water spray by Concrete Pump Truck

Current Conditions: Fresh water is being injected to the Spent Fuel Pool and the core

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 4 (As of 6:00 April 2nd, 2011)




Major events after the earthquake

- In periodic inspection outage when the earthquake occurred
- 14th 04:08 Water temperature in the Spent Fuel Pool (SFP), 84°C
- 15th 06:14 Confirmed the partial damage of wall in the 4th floor.
- 15th 09:38 Fire occurred in the 3rd floor. (12:25 extinguished)
- 16th 05:45 Fire occurred. TEPCO couldn't confirm any fire on the ground. (06:15)
- 20th 08:21~09:40 Water spray over SFP by Self-Defense Force
- 20th around 18:30~19:46 Water spray over SFP by Self-Defense Force
- 21st 06:37~08:41 Water spray over SFP by Self-Defense Force
- 21st about 15:00 Work for laying cable to Power Center was completed.
- 22nd 10:35 Power Center received electricity.
- 22nd 17:17~20:32 Water spray by Concrete Pump Truck
- 23rd 10:00~13:02 Water spray by Concrete Pump Truck
- 24th 14:36~17:30 Water spray by Concrete Pump Truck
- 25th 06:05~10:20 Sea water injection to SFP via the Fuel Pool Cooling Line (FPC)
- 25th 19:05~22:07 Water spray by Concrete Pump Truck
- 27th 16:55~19:25 Water spray by Concrete Pump Truck
- 29th 11:50 Lighting in the Central Control Room was recovered.
- 30th 14:04~18:33 Water spray by Concrete Pump Truck (Fresh water)
- 1st 8:28~14:14 Water spray by Concrete Pump Truck (Fresh water)

Current Conditions: No fuel is in RPV*³.
Fresh water is being injected to the Spent Fuel Pool.


(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 5 (As of 6:00 April 2nd, 2011)



(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 6 (As of 6:00 April 2nd, 2011)



(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)