

April 19, 2011

Nuclear and Industrial Safety Agency

**Seismic Damage Information (the 102nd Release)**  
(As of 15:00 April 19th, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- The stagnant water (stagnant water with high-level radioactivity) in the turbine building of Unit 2 was started to be transferred to the Radioactive Waste Treatment Facilities (From 10:08 April 19th)
- Fresh water spray of around 40t over the Spent Fuel Pool of Unit 4 using Concrete Pump Truck (62m class) was carried out. (From 10:17 till 11:35 April 19th)
- Work of strengthening connection of the power supplies between Units 1 and 2 and Units 3 and 4 was completed. (10:23 April 19th)

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

April 20, 2011

Nuclear and Industrial Safety Agency

**Seismic Damage Information (the 103rd Release)**  
(As of 08:00 April 20th, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- Fresh water injection (Around 47t) to the Spent Fuel Pool via the Spent Fuel Pool Cooling Line of Unit 2 was carried out. (From 16:08 till 17:28 April 19th)
- Injection of around 17,000L on April 18th and around 7,000L on April 19th of the coagulant (soluble glass) to the Power Cable Trench of Unit 2 was carried out.
- The stagnant water in the basement floor of the turbine building of Unit 6 (Around 100 m<sup>3</sup>) was transferred to the Condenser. (From 11:00 till 15:00 April 19th)
- Removal of rubble (Amounts equivalent to 3 containers) using remote-control heavy machineries was carried out. (From 9:00 till 15:00 April 19th)

For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

April 20, 2011

Nuclear and Industrial Safety Agency

**Seismic Damage Information (the 104rd Release)**  
(As of 15:30 April 20th, 2011)

Nuclear and Industrial Safety Agency (NISA) confirmed the current situation of Onagawa NPS, Tohoku Electric Power Co. Inc.; Fukushima Dai-ichi and Fukushima Dai-ni NPSs, Tokyo Electric Power Co. Inc. (TEPCO); Tokai Dai-ni NPS, Japan Atomic Power Co. Inc. as follows:

Major updates are as follows.

1. Nuclear Power Stations (NPSs)

● Fukushima Dai-ichi NPS

- The work of sampling water that flowed out in the Skimmer Surge Tank from the Spent Fuel Pool of Unit 2 was carried out in order to grasp the condition of water in the pool. (April 16th) As a result of nuclide analysis of radioactive materials regarding the sampled water of the pool,  $4.1 \times 10^3 \text{Bq/cm}^3$  of  $^{131}\text{I}$  (Iodine),  $1.6 \times 10^5 \text{Bq/cm}^3$  of  $^{134}\text{Cs}$  (Caesium),  $1.5 \times 10^5 \text{Bq/cm}^3$  of  $^{137}\text{Cs}$  (Caesium) were detected. (April 17th)
- The pump for Residual Heat Removal (RHR) was temporarily stopped in order to change the position of the hose of the temporary RHR Seawater System of Unit 6. (From 09:51 April 20th)

<Directives regarding foods and drinks>

Items under the suspension of shipment and restriction of intake were updated. (As of 15:30 April 20th)


For more information:

NISA English Home Page

<http://www.nisa.meti.go.jp/english/index.html>

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 1 (As of 13:00 April 19th, 2011)

## Major Events after the Earthquake




- March 11<sup>th</sup> 14:46 Under operation, Automatic shutdown by the earthquake
- March 11<sup>th</sup> 15:42 Report based on the Article 10 (Total loss of A/C power)
- March 11<sup>th</sup> 16:36 Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System)
- March 12<sup>th</sup> 01:20 Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)
- March 12<sup>th</sup> 10:17 Started to vent.
- March 12<sup>th</sup> 15:36 Sound of explosion
- March 12<sup>th</sup> 20:20 Started to inject seawater and borated water to the Reactor Core.
- March 23<sup>rd</sup> 02:33 The amount of injected water to the Reactor Core was increased utilizing the Feedwater Line in addition to the Fire Extinguish Line. (2m<sup>3</sup>/h →18m<sup>3</sup>/h)  
09:00 Switched to the Feedwater Line only.(18m<sup>3</sup>/h →11m<sup>3</sup>/h)
- March 24<sup>th</sup> 11:30 Lighting in the Central Control Room was recovered.
- March 25<sup>th</sup> 15:37 Started to inject fresh water.
- March 29<sup>th</sup> 08:32 Switched to the water injection to the Reactor Core using the temporary motor-driven pump.
- March 31<sup>st</sup> 12:00 ~2<sup>nd</sup> 15:26 Started to transfer the stagnant water from the Condensate Storage Tank (CST) to the Surge Tank of Suppression Pool Water (SPT)
- March 31<sup>st</sup> 13:03~16:04 Water spray by Concrete Pump Truck (Fresh water)
- April 3<sup>rd</sup> 12:02 The power supply to the temporary motor-driven pump was switched from the temporary power supply to the external power supply.
- April 3<sup>rd</sup> 13:55 Started to transfer the water from the Condenser to CST.
- April 6<sup>th</sup> 22:30 Started the operation for the injection of nitrogen to PCV.
- April 7<sup>th</sup> 01:31 Confirmed starting the injection of nitrogen to PCV.
- April 9<sup>th</sup> 04:10 Started using highly pure nitrogen generator in the injection of nitrogen to PCV.
- April 10<sup>th</sup> 09:30 Completed transferring the water from the Condenser to CST.
- April 11<sup>th</sup> around 17:16 Loss of external power supply due to an earthquake occurred (at Hamadori in Fukushima Prefecture) and water injection to the Reactor Core and nitrogen injection to PCV were suspended.
- April 11<sup>th</sup> 17:56 External power supply was recovered.
- April 11<sup>th</sup> 18:04 Resumed injecting water to the Reactor Core.
- April 11<sup>th</sup> 23:19 Restarted operation for injecting nitrogen to PCV.
- April 11<sup>th</sup> 23:34 Confirmed starting injection of nitrogen to PCV.
- April 17<sup>th</sup> 16:00~17:30 Confirmed the situation in the reactor building using an unmanned robot.
- April 18<sup>th</sup> 11:50~12:12 Stopped the water injection into the reactor core to replace the current hose with a new one

\*1 Residual Heat Removal System  
\*2 Emergency Diesel Generator  
\*3 Primary Containment Vessel  
\*4 Suppression Pool

**Current Conditions : Fresh water is being injected to the Spent Fuel Pool and the Reactor Core**

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 2 ( As of 13:00 April 19th, 2011 )



## Major Events after the Earthquake 1/2

- March 11<sup>th</sup> 14:46 Under operation, Automatic shutdown by the earthquake
- March 11<sup>th</sup> 15:42 Report based on the Article 10 (Total loss of A/C power)
- March 11<sup>th</sup> 16:36 Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System )
- March 13<sup>th</sup> 11:00 Started to vent.
- March 14<sup>th</sup> 13:25 Occurrence of the Article 15 event (Loss of reactor cooling functions)
- March 14<sup>th</sup> 16:34 Started to inject seawater to the Reactor Core.
- March 14<sup>th</sup> 22:50 Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)
- March 15<sup>th</sup> 00:02 Started to vent.
- March 15<sup>th</sup> 06:10 Sound of explosion
- March 15<sup>th</sup> around 06:20 Possible damage of the suppression chamber
- March 20<sup>th</sup> 15:05~17:20 Approximately 40 ton seawater injection to the Spent Fuel Pool (SFP) via the Fuel Pool Cooling Line (FPC)
- March 20<sup>th</sup> 15:46 Power Center received electricity.
- March 21<sup>st</sup> 18:22 White smoke generated. The smoke died down and almost invisible at 07:11 March 22<sup>nd</sup>.
- March 22<sup>nd</sup> 16:07 Injection of around 18 tons of seawater to SFP
- March 25<sup>th</sup> 10:30~12:19 Sea water injection to SFP via FPC
- March 26<sup>th</sup> 10:10 Started to inject fresh water to the Reactor Core.
- March 26<sup>th</sup> 16:46 Lighting in the Central Control Room was recovered.
- March 27<sup>th</sup> 18:31 Switched to the water injection to the core using the temporary motor-driven pump.
- March 29<sup>th</sup> 16:30~18:25 Switched to the temporary motor-driven pump injecting fresh water to SFP.
- March 29<sup>th</sup> 16:45~1<sup>st</sup> 11:50 Transferred the water from the Condensate Storage Tank (CST) to the Surge Tank of Suppression Pool Water (SPT)
- March 30<sup>th</sup> 9:25~23:50 Confirmed malfunction of the temporary motor-driven pump injecting fresh water to SFP(9:45). Switched to the injection using the fire pump Truck, but suspended as cracks were confirmed in the hose. (12:47, 13:10) Resumed injection of fresh water(19:05)
- April 1<sup>st</sup> 14:56~17:05 Freshwater injection to SFP via FPC using the temporary motor-driven pump.
- April 2<sup>nd</sup> around 9:30 The water, of which the dose rate was at the level of more than 1,000mSv/h, was confirmed to be collected in the pit located near the Intake Channel of Unit 2. The outflow from the lateral surface of the pit into the sea was also confirmed.
- April 2<sup>nd</sup> 17:10 Started to transfer the water from the Condenser to the CST.
- April 3<sup>rd</sup> 12:12 The power supply to the temporary motor-driven pump was switched from the temporary power supply to the external power supply.
- April 3<sup>rd</sup> 13:47~14:30 20 bags of sawdust, 80 bags of high polymer absorbent and 3 bags of cutting-processed newspaper were put into the Pit for the Conduit.
- April 4<sup>th</sup> 7:08~7:11 Approximately 13kg of tracer (bath agent) was put in from the Pit for the Duct for Seawater Pipe.
- April 4<sup>th</sup> 11:05~13:37 Freshwater Injection to SFP via FPC using the temporary motor-driven pump.
- April 5<sup>th</sup> 14:15 Tracer is confirmed to outflow through the permeable layer around the pit into the sea. 15:07 Started to inject coagulant.
- April 6<sup>th</sup> around 5:38 The water outflow from the lateral surface of the pit was confirmed to stopped.
- April 7<sup>th</sup> 13:29~14:34 Freshwater injection to SFP via FPC (Around 36 ton)
- April 9<sup>th</sup> 13:10 Completed transferring the water from the Condenser to CST.
- April 10<sup>th</sup> 10:37~12:38 Freshwater injection to SFP via FPC using the temporary motor-driven pump (Around 60 ton).
- April 11<sup>th</sup> around 17:16 Loss of external power supply due to an earthquake occurred (at Hamadori in Fukushima Prefecture). Water injection to the Reactor Core was suspended.
- April 11<sup>th</sup> 17:56 External power supply was recovered.
- April 11<sup>th</sup> 18:04 Resumed injecting water to the Reactor Core.

- \*1 Residual Heat Removal System
- \*2 Emergency Diesel Generator
- \*3 Primary Containment Vessel
- \*4 Suppression Pool

Current Conditions: Fresh water is being injected to the Spent Fuel Pool and the Reactor Core

## Major Events after the Earthquake 2/2

April 12<sup>th</sup> 19:35~April 13<sup>th</sup> 17:04 Transfer from the trench of the turbine building to the Condenser.

April 13<sup>th</sup> 11:00 Suspended the transfer for checking leaks, etc.

April 13<sup>th</sup> 13:15~14:55 Freshwater injection to SFP via FPC using the temporary motor-driven pump.

April 16<sup>th</sup> 10:13~11:54 Freshwater injection to SFP via FPC using the temporary motor-driven pump. (The temporary motor-driven pump stopped at 11:39 due to an earthquake that occurred at around 11:19. SFP was confirmed to be filled to capacity through observing a rise of the water level in the Skimmer Tank.)


April 16<sup>th</sup> around 11:19 An earthquake occurred (in the southern part of Ibaraki Prefecture).

April 18<sup>th</sup> 13:42~ Confirmed the situation in the reactor building using an unmanned robot.

April 18<sup>th</sup> 12:13~12:37 Stopped the water injection into the reactor core to replace the current hose with a new one.

April 19<sup>th</sup> 10:08~ Started to transfer the stagnant water with high-level radioactivity from the trench of the turbine building to the buildings of radioactive waste treatment facilities.

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 3 ( As of 13:00 April 19th, 2011 )



- \*1 Residual Heat Removal System
- \*2 Emergency Diesel Generator
- \*3 Primary Containment Vessel
- \*4 Suppression Pool


(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

**Current Conditions: Fresh water is being injected to the Spent Fuel Pool and the Reactor Core**

## Major Events after the Earthquake

March 11 <sup>th</sup> 14:46	Under operation, Automatic shutdown by the earthquake
March 11 <sup>th</sup> 15:42	Report based on the Article 10 (Total loss of A/C power)
March 13 <sup>th</sup> 05:10	Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System)
March 13 <sup>th</sup> 08:41	Started to vent.
March 13 <sup>th</sup> 13:12	Started to inject seawater and borated water to the Reactor Core.
March 14 <sup>th</sup> 05:20	Started to vent.
March 14 <sup>th</sup> 07:44	Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)
March 14 <sup>th</sup> 11:01	Sound of explosion
March 16 <sup>th</sup> around 08:30	White smoke generated.
March 17 <sup>th</sup> 09:48~10:01	Water discharge by the helicopters of Self-Defense Force
March 17 <sup>th</sup> 19:05~19:15	Water spray from the ground by High pressure water-cannon trucks of Police
March 17 <sup>th</sup> 19:35~20:09	Water spray from the ground by fire engines of Self-Defense Force
March 18 <sup>th</sup> before 14:00~14:38	Water spray from the ground by 6 fire engines of Self-Defense Force
March 18 <sup>th</sup> ~14:45	Water spray from the ground by a fire engine of the US Military
March 19 <sup>th</sup> 00:30 ~ 01:10	Water spray by Hyper Rescue Unit of Tokyo Fire Department
March 19 <sup>th</sup> 14:10 ~ 20 <sup>th</sup> 03:40	Water spray by Hyper Rescue Unit of Tokyo Fire Department
March 20 <sup>th</sup> 11:00	Pressure of PCV rose(320kPa).Afterward fell.
March 20 <sup>th</sup> 21:36 ~ 21 <sup>st</sup> 03:58	Water spray by Hyper Rescue Unit of Tokyo Fire Department
March 21 <sup>st</sup> around 15:55	Grayish smoke generated and was confirmed to be died down at 17:55.
March 22 <sup>nd</sup> 15:10 ~ 16:00	Water spray by Hyper Rescue Unit of Tokyo Fire Department and Osaka City Fire Bureau.
March 22 <sup>nd</sup> 22:46	Lighting in the Central Control Room was recovered.
March 23 <sup>rd</sup> 11:03 ~ 13:20	Injection of about 35 ton of sea water to the Spent Fuel Pool (SFP) via the Fuel Pool Cooling Line (FPC)
March 23 <sup>rd</sup> around 16:20	Black smoke generated and was confirmed to died down at around 23:30 and 24 <sup>th</sup> 04:50.
March 24 <sup>th</sup> 05:35 ~ 16:05	Injection of around 120 ton of sea water to SFP via FPC
March 25 <sup>th</sup> 13:28 ~ 16:00	Water spray by Kawasaki City Fire Bureau supported by Tokyo Fire Department
March 25 <sup>th</sup> 18:02	Started fresh water injection to the core.
March 27 <sup>th</sup> 12:34 ~ 14:36	Water spray by Concrete Pump Truck
March 28 <sup>th</sup> 17:40 ~ 31 <sup>st</sup> around 8:40	Transferring the water from the Condensate Storage Tank (CST) to the Surge Tank of Suppression Pool Water (SPT)
March 28 <sup>th</sup> 20:30	Switched to the water injection to the core using a temporary motor-driven pump.
April 3 <sup>rd</sup> 12:18	The power supply to the temporary motor-driven pump was switched from the temporary power supply to the external power supply.
April 11 <sup>th</sup> around 17:16	Loss of external power supply of Unit 1 and 2 due to an earthquake occurred (at Hamadori in Fukushima Prefecture) and water injection to the Reactor Core was suspended.
April 11 <sup>th</sup> 18:04	External power supply of Units 1 and 2 recovered (April 11 <sup>th</sup> 17:56). Resumed injecting water to the Reactor Core.
April 17 <sup>th</sup> 11:30 ~ 14:00	Confirmed the situation in the reactor building using unmanned robot.
April 18 <sup>th</sup> 12:38 ~ 13:05	Stopped the water injection into the reactor core to replace the current hose with a new one
<Water spray by Concrete Pump Truck (Fresh water)>	
March 29 <sup>th</sup> 14:17 ~ 18:18, March 31 <sup>st</sup> 16:30 ~ 19:33, April 2 <sup>nd</sup> 09:52 ~ 12:54, April 4 <sup>th</sup> 17:03 ~ 19:19, April 7 <sup>th</sup> 06:53 ~ 08:53, April 8 <sup>th</sup> 17:06 ~ 20:00, April 10 <sup>th</sup> 17:15 ~ 19:15, April 12 <sup>th</sup> 16:26 ~ 17:16, April 14 <sup>th</sup> 15:56 ~ 16:32, April 18 <sup>th</sup> 14:17 ~ 15:02	

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 4 ( As of 13:00 April 19th, 2011 )



- \*1 Residual Heat Removal System
- \*2 Emergency Diesel Generator
- \*3 Reactor Pressure Vessel

## Major Events after the Earthquake

In periodic inspection outage when the earthquake occurred  
 March 14<sup>th</sup> 04:08 Water temperature in the Spent Fuel Pool (SFP), 84°C  
 March 15<sup>th</sup> 06:14 Confirmed the partial damage of wall in the 4<sup>th</sup> floor.  
 March 15<sup>th</sup> 09:38 Fire occurred in the 3<sup>rd</sup> floor. (12:25 extinguished)  
 March 16<sup>th</sup> 05:45 Fire occurred. TEPCO couldn't confirm any fire on the ground. (06:15)  
 March 20<sup>th</sup> 08:21~09:40 Water spray over SFP by Self-Defense Force  
 March 20<sup>th</sup> around 18:30~19:46 Water spray over SFP by Self-Defense Force  
 March 21<sup>st</sup> 06:37~08:41 Water spray over SFP by Self-Defense Force  
 March 21<sup>st</sup> around 15:00 Work for laying cable to Power Center was completed.  
 March 22<sup>nd</sup> 10:35 Power Center received electricity.  
 <Water spray by Concrete Pump Truck (Seawater)>  
 March 22<sup>nd</sup> 17:17~20:32, March 23<sup>rd</sup> 10:00~13:02, March 24<sup>th</sup> 14:36~17:30, March 25<sup>th</sup> 19:05~22:07, March 27<sup>th</sup> 16:55~19:25  
 March 25<sup>th</sup> 06:05~10:20 Sea water injection to SFP via the Fuel Pool Cooling Line (FPC)  
 March 29<sup>th</sup> 11:50 Lighting in the Central Control Room was recovered.  
 April 11<sup>th</sup> around 17:16 An earthquake occurred (at Hamadori in Fukushima Prefecture).  
 April 12<sup>th</sup> 12:00~13:04 Sampled the water in SFP.


< Water spray by Concrete Pump Truck (Fresh water)> March 30<sup>th</sup> 14:04~18:33, April 1<sup>st</sup> 08:28~14:14, April 3<sup>rd</sup> 17:14~22:16, April 5<sup>th</sup> 17:35~18:22, April 7<sup>th</sup> 18:23~19:40, April 9<sup>th</sup> 17:07~19:24, April 13<sup>th</sup> 0:30~6:57, April 15<sup>th</sup> 14:30~18:29, April 17<sup>th</sup> 17:39~21:22, April 19<sup>th</sup> 10:17~11:35

**Current Conditions: No fuel is in RPV\*3.  
Fresh water is being injected to the Spent Fuel Pool.**

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)




# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 5 ( As of 13:00 April 19th, 2011 )



※Heat removal was carried out alternately with the water in the Reactor Core and in the Spent Fuel Pool.

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 6 ( As of 13:00 April 19th, 2011 )



**Major Events after the Earthquake:**  
 March 20<sup>th</sup> 19:27 Cold shutdown  
 March 22<sup>nd</sup> 19:17 Receiving electricity from external power supply  
 April 4<sup>th</sup> 21:00 – 9<sup>th</sup> 18:52 Discharged the groundwater with low-level radioactivity in the Sub Drain Pit to the sea (around 373 ton).

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)